

Welltag id: ALQ090

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. 35140
Water Right Permit No.

(1) OWNER: Name TODD, BILL Address 6120 CABBELL RD S CLINTON, WA 98236-
(2) LOCATION OF WELL: County ISLAND
(2a) STREET ADDRESS OF WELL (or nearest address) 6120 CABBELL RD S
(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well (If more than one) 1
NEW WELL Method: ROTARY
(5) DIMENSIONS: Diameter of well 6 inches
Drilled 187 ft. Depth of completed well 184.5 ft.
(6) CONSTRUCTION DETAILS: Casing installed: 6
WELDED
Dia. from +2 ft. to 180.5 ft.
Dia. from ft. to ft.
Dia. from ft. to ft.

Perforations: NO
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES
Manufacturer's Name JOHNSON
Type STAINLESS STEEL Model No. K2
Diam. 6 slot size 10 from 179.5 ft. to 184.5 ft.
Diam. slot size from ft. to ft.

Gravel packed: NO
Gravel placed from ft. to ft. Size of gravel ft.

Surface seal: YES To what depth? 18 ft.
Material used in seal PUDDLING CLAY
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off

(7) PUMP: Manufacturer's Name Type H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 155.7 ft. below top of well Date 08/31/89
Artesian Pressure lbs. per square inch Date
Artesian water controlled by

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? NO If yes, by whom? hrs.
Yield: gal./min with ft. drawdown after

Recovery data
Time Water Level Time Water Level Time Water Level

Date of test / /
Bailer test 15 gal./min. 15 ft. drawdown after 1 hrs.
Air test gal./min. w/ stem set at ft. for hrs.
Artesian flow g.p.w. Date
Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
TAN GRAVEL SAND & CLAY	0	60
DIRTY GRAY SAND	60	165
TAN SAND GRAVEL & CLAY	165	175
GRAY CLAY SAND & WOOD	175	176
GRAY SAND & WOOD & WATER	176	186
GRAY CLAY & SILT	186	

RECEIVED
SEP 7 1989

DEPARTMENT OF ECOLOGY
NORTHWEST REGION

Work started 08/30/89 Completed 08/31/89

WELL CONSTRUCTOR CERTIFICATION:
I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.
(Person, firm, or corporation) (Type or print)

ADDRESS 556 ERSKIG RD. BOW
(SIGNED) Steve Hayes License No. 762

Contractor's Registration No. HAYESWD1870W Date 09/01/89

RECEIVED

FEB 26 2008

DEPT. OF ECOLOGY

WATER WELL REPORT
STATE OF WASHINGTONStart Card No. 35140
Water Right Permit No.

(1) OWNER: Name TODD, BILL

Address 6120 CAMELL RD S CLINTON, WA 98236-

(2) LOCATION OF WELL: County ISLAND

- SW 1/4 NE 1/4 Sec 23 T 29 N., R 3E WM

(2a) STREET ADDRESS OF WELL (or nearest address) 6120 CAMELL RD S

(3) PROPOSED USE: DOMESTIC

(10) WELL LOG

(4) TYPE OF WORK:

Owner's Number of well
(If more than one) 1
Method: ROTARY

NEW WELL

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

(5) DIMENSIONS:

Diameter of well 6 inches

Drilled 187 ft. Depth of completed well 184.5 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6
WELDED
Dia. from +2 ft. to 180.5 ft.
Dia. from ft. to ft.
Dia. from ft. to ft.

MATERIAL

TAN GRAVEL SAND & CLAY

DIRTY GRAY SAND

TAN SAND GRAVEL & CLAY

GRAY CLAY SAND & WOOD

GRAY SAND & WOOD & WATER

GRAY CLAY & SILT

FROM	TO
0	60
60	165
165	175
175	176
176	186

Perforations: NO

Type of perforator used

SIZE of perforations

	ft. to	in. by	ft. to	in.
perforations from				
perforations from				
perforations from				

Screens: YES

Manufacturer's Name

JOHNSON

Type STAINLESS STEEL

Model No. K2

Diam. 6 slot size 10

from 179.5 ft. to 184.5 ft.

Diam. slot size

from ft. to ft.

Gravel packed: NO

Size of gravel

Gravel placed from ft. to ft.

Surface seal: YES

To what depth? 18 ft.

Material used in seal PUDDLING CLAY

Did any strata contain unusable water? NO

Type of water?

Depth of strata ft.

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type

H.P.

(8) WATER LEVELS:

Land-surface elevation

above mean sea level ... ft.

Static level 155.7 ft. below top of well Date 08/31/89

Artesian Pressure lbs. per square inch Date

Artesian water controlled by

Work started 08/30/89

Completed 08/31/89

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?

Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time	Water Level	Time	Water Level	Time	Water Level
------	-------------	------	-------------	------	-------------

Date of test / /

Bailer test 15 gal./min. 15 ft. drawdown after 1 hrs.

Air test gal./min. w/ stem set at ft. for hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME HAYES DRILLING, INC.

(Person, firm, or corporation) (Type or print)

ADDRESS 556 ERSKINE RD.

BOW

[SIGNED] Steve Hayes License No. 762

Contractor's

Registration No. HAYESWD1870W

Date 09/01/89